

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

See violation comments for violation items #5 and 18.

eshannon1@ecsdfl.us
janderson@ecsdfl.us
ejones2@ecsdfl.us
jhiggins@ecsdfl.us

Mr. Anderson 8504490114

Email Address(es): eshannon1@ecsdfl.us;
janderson@ecsdfl.us;
ejones2@ecsdfl.us;
jhiggins@ecsdfl.us

Violations Comments

Violation #5. Maintenance & Repair

- Boys restroom 135: Observed sign posted at restroom indicating that it is restroom closed for repairs. Work order has been submitted for this item. Repair as needed
- Observed dusty overhead vents and ceiling tiles with water damage at 900 wing common area where the snack vending machines are located (solarium wing). Clean vents as needed and maintain clean condition. Repair/Replace damaged ceiling tiles as needed.
- Observed water damage on tiles in hall by classroom 906 and inside classroom 906. Repair/Replace as needed.
- Observed water damage on multiple tiles in the PE building near mechanical room 314. Repair/Replace as needed.
- 900 wing carpet soiled at entry/exit points. Vacuum/clean carpet as needed and maintain clean condition.
- Building 4 - Carpet soiled at entry/exit points throughout the building. Vacuum/clean carpet as needed and maintain clean condition.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

- Drinking fountain in main office (back of office near restroom) has sign posted indicating that the bottle filler station is not in order due to silt content. Inspect this unit to ensure the water is safe for drinking. Repair/Replace, if needed.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Christie Gillenwater (027985)
Inspector Contact Number: Work: (850) 595-6700 ex. 2006
Print Client Name: Jeff Anderson
Date: 3/24/2023

Inspector Signature:

Handwritten signature of Christie Gillenwater.

Client Signature:

Handwritten signature of Jeff Anderson, marked with an 'X' at the beginning.